



Ontario County Public Works

William C. Wright, P.E.
Commissioner of
Public Works
Office: (585) 396-4000

2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

John E. Berry, P.E.
Deputy Commissioner
of Public Works
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

September 26, 2019

Justin W. Kellogg P.E.
Meagher Engineering
2024 West Henrietta Road, Suite 2C
Rochester, New York 14623

Re: Dean and Aleta Williamson
4962 Station House Drive
Canandaigua, N.Y. 14424

Dear Mr. Kellogg,

We are in receipt of a site plan set for the referenced project dated September 19, 2019.

GENERAL

1. Renovation permit required for renovation.

SITE PLAN

1. A foundation sleeve of at least 6 inches is required for laterals that do not enter under slab.
2. Label 8 inch **AC** pipe on sewer main shown on drawing.
3. If the current lateral and tap are to be reused it has to be televised and witnessed by District staff to determine viability for reuse.
4. If the current lateral is SDR-35 the same material can be reused if it has been deemed acceptable after televising.
5. Label Southern man hole M-87.
6. Add cleanouts every 90 feet and change of direction.

Please make revisions and resubmit to our office and after approval we will issue a lateral permit. If you have any questions I may be reached at (585) 396-4301

Sincerely,

Donald E. Havens, Jr.
Supervisor, Canandaigua Lake Sewer District

cc: John E. Berry, P.E., Deputy Commissioner of Public Works
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua