



# Ontario County Public Works

William C. Wright, P.E.  
Commissioner of  
Public Works  
Office: (585) 396-4000

2962 County Road 48  
Canandaigua, New York 14424-9553  
www.co.ontario.ny.us  
email: dpw@co.ontario.ny.us

John E. Berry, P.E.  
Deputy Commissioner  
of Public Works  
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

August 30, 2019

Erin Venezia Joyce P.E.  
Venezia Land Surveyors and Civil Engineers  
5120 Laura Lane  
Canandaigua, New York 14424

Re: Robyn Relph  
4966 Station House Drive  
Canandaigua, N.Y. 14424

Dear Mrs. Venezia-Joyce

We are in receipt of a site plan set for the referenced project dated August 9, 2019.

## GENERAL

1. Renovation permit required for renovation.

## SITE PLAN

1. A foundation sleeve of at least 6 inches is required for laterals that do not enter under slab.
2. Label 8 inch AC pipe on sewer main shown on drawing.
3. If the current lateral and tap are to be reused it has to be televised and witnessed by District staff to determine viability for reuse.
4. If the current lateral is SDR-35 the same material can be reused if it has been deemed acceptable after televising.
5. Relabel 6" SDR-21 to 4" SDR-21 on the two locations of new lateral.
6. Remove "Inserta Tee" Detail.

Please make revisions and resubmit to our office and after approval we will issue a lateral permit. If you have any questions I may be reached at (585) 396-4301

Sincerely,

  
Donald E. Havens, Jr.  
Supervisor, Canandaigua Lake Sewer District

cc: John E. Berry, P.E., Deputy Commissioner of Public Works  
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua