



CITY OF CANANDAIGUA FIRE DEPARTMENT

Fire Chief Frank Magnera
335 South Main Street
Canandaigua, NY 14424-2118
Phone (585) 396-5052 Fax (585) 394-2706



Plan Review Comments

Application CPN-20-010

0000 Thomas Road, Canandaigua, NY

March 09, 2020

To whom this may concern:

The Fire Department comments regarding the proposed Site Plan for 0000 Thomas Road:

- What safeguards / protection of the Petroleum Pipeline will be in place during and after construction?
- Other than the Pipelines, if any, what other Constrained Land issue are present? Flooding, erosion etc.? This is in regard to Access Roads.
- Please work with the Fire Chief on future **Site and Utility plans** for Fire Hydrant Locations and Fire Apparatus Access Roadways.

No further comments.

If you have any questions feel free to contact me. Thank you.

Respectfully,

Frank A. Magnera

Frank Magnera, MS, CFPS
Fire Chief & Fire Marshal