



# CITY OF CANANDAIGUA FIRE DEPARTMENT

**Fire Chief Frank Magnera**  
335 South Main Street  
Canandaigua, NY 14424-2118  
Phone (585) 396-5052 Fax (585) 394-2706



---

## Plan Review Comments

Application CPN-19-087  
5600 Thomas Road, Canandaigua, NY

November 26, 2018

To whom this may concern:

The Fire Department comments regarding the proposed Site Plan regarding 5600 Thomas Road.

- Please ensure permanent gravel driveway is capable of supporting the imposed load of fire apparatus weighing at least 75,000 pounds. (FC D102.1 Access and Loading)

No further comments.

If you have any questions feel free to contact me. Thank you.

Respectfully,

*Frank A. Magnera*

Frank Magnera, MS, CFPS  
Fire Chief & Fire Marshal