



Ontario County Public Works

William C. Wright, P.E.
Commissioner of
Public Works
Office: (585) 396-4000

2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

John E. Berry, P.E.
Deputy Commissioner
of Public Works
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

March 3, 2016

Rocco A. Venezia
Venezia Land Surveyors and Civil Engineers
5120 Laura Lane
Canandaigua, New York 14424

Re: Jeffrey and Laurie Twombly
4341 Tichnor Point Drive
Canandaigua, New York 14424

Dear Mr. Venezia:

We are in receipt of a site plan set for the referenced project dated February 22, 2016.

GENERAL

1. Renovation permit required for connection.

SITE PLAN

1. If reusing any portion of the existing sanitary sewer lateral serving the property must be televised for condition and a copy given to the district for evaluation.
2. If lateral is deemed in good condition the use of the 4 inch SDR 35 pipe may be used to return service to the property. Should it need to be replaced 4 inch SDR 21 must be used to replace the lateral.
3. Add "Standard Sanitary Lateral Plan Notes".
4. Remove current clean out detail.
5. Add District clean out detail.
6. Add lateral trench and bedding detail.
7. Add Sanitary Sewer Lateral Detail.
8. Label 8 inch AC pipe on sewer main shown on drawing.
9. Show location of MH 69
10. Correct all rim and invert elevations on man holes MH 69 and MH 70.
11. Add water main on drawing.
12. Add water service connection on drawing.

Please make revisions and resubmit to our office. If you have any questions I may be reached at (585) 396-4301

Sincerely,

Donald E. Havens, Jr.
Supervisor, Canandaigua Lake Sewer District

Enc.

cc: John E. Berry, P.E., Deputy Commissioner of Public Works (w/o enc.)
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua (w/o enc.)
Doug Finch, Director of Development, Town of Canandaigua (w/o enc.)