



Ontario County Public Works

William C. Wright, P.E.
Commissioner of
Public Works
Office: (585) 396-4000

2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

John E. Berry, P.E.
Deputy Commissioner
of Public Works
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

FILE

August 25, 2016

Rocco A. Venezia
Venezia Land Surveyors and Civil Engineers
5120 Laura Lane
Canandaigua, New York 14424

Re: John D. Bartholf
4959 Waters Edge Drive
Canandaigua, N.Y. 14424

TOWN OF CANANDAIGUA		
DEVELOPMENT OFFICE		
R E C E I V E D	<div style="border: 1px solid black; padding: 10px; text-align: center;">AUG 29 2016</div>	F O R R E V I E W

Dear Mr. Venezia:

We are in receipt of a site plan set for the referenced project dated August 23, 2016.

GENERAL

1. Renovation permit required for connection.

SITE PLAN

1. Add District clean out detail.
2. If the existing lateral is to be reused be aware that the district requires that the applicant televise the lateral to deem its viability.
3. Explain the need for the lateral into the garage and its proposed use.
4. Local law requires a separate lateral for each structure
- 5.40 - Separate building sewers required

A separate and independent building sewer shall be provided for every building; except where one building stands at the rear of another on an interior lot and no private sewer is available or can be constructed to the rear building through an adjoining alley, court, yard, or driveway, the building sewer from the front building may be extended to the rear building and the whole considered as one building sewer.

5. Although the situation exists where one building stands at the rear of another the district will require that the laterals from both structures be tied together outside the structures to the North via a wye connection.
6. Label new lateral 4" SDR 35 with cleanouts every 90 feet and within 3 feet of proposed structures.

Please make revisions and resubmit to our office and after approval we will issue a lateral permit. If you have any questions I may be reached at (585) 396-4301

Sincerely,


Donald E. Havens, Jr.
Supervisor, Canandaigua Lake Sewer District

Enc.

cc: John E. Berry, P.E., Deputy Commissioner of Public Works (w/o enc.)
Doug Finch, Director of Development, Town of Canandaigua (w/o enc.)
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua (w/o enc.)