

**From:** [Havens, Donald E](#)  
**To:** [devclerk@townofcanandaigua.org](mailto:devclerk@townofcanandaigua.org)  
**Cc:** [May, Steven P](#)  
**Subject:** Application Comments  
**Date:** Friday, April 2, 2021 9:12:07 AM

---

Hi Michelle,

The Canandaigua Lake Sewer District has the following comment for the following application.

- CPN-21-028 – Permit Required for connection along with plan review.
- CPN-21-029 - Permit Required for connection along with plan review.
- CPN-21-030 - Permit Required for connection along with plan review. Pretreatment units will be required for this type of facility and a bypass pumping plan will also be required.

Thanks,  
Don

**Don Havens**  
**Canandaigua Lake County Sewer District Supervisor**  
**Ontario County Public Works Department**  
**2962 County Road # 48**  
**Canandaigua, N.Y. 14424-9553**  
**Office (585) 396-4301**  
**Office Hours: M-F 7:00 AM to 3:30 PM**



“This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.”