

Comments for the planning and zoning board March 2021 by Highway and water superintendent

- ATL contractors. Application # CPN-21-030.
 - Open cutting of Emerson road is not allowed. Directional drill under the road to connect to the sanitary sewer.
 - Water is operated by Canandaigua Farmington water district.
- Aikey Property application # CPN -21-010
 - Remove the landscape screening from the Canandaigua consolidated water main easement along county road 10
 - Any landscaping should be a minimum of 30 feet from edge of easement.
 - Any work to be performed in the easement of the water main must contact the water superintendent prior to starting work.
- Jerry and Lori Reinhart Application # CPN-21-029
 - Applicant will need to submit and pay for the water service before tapping of the water main.
 - The fee for tapping water main and water meter is \$ 1,757.00
 - How will the water meter be mounted inside the house? The meter is 13-inch-long x 4-inch-wide x 4 inches tall. This is for a 1.5-inch water meter.
 - Pressure reducing valve is needed after the water meter.
 - Water meter needs to be accessible to the town for any service-related repairs.
 - If an irrigation system is being proposed an engineered plan must be submitted to the town and to the dept of health for approval.
 - Water meter must be kept in a temperature conditioned room
- Chuck and Kate Vasilius Application # CPN-21-028
 - Applicant will need to submit and pay for the water service before tapping of the water main.
 - Water curb stop will stay within the easement of the water main.
 - The fee for tapping water main and water meter is \$ 1,757.00
 - How will the water meter be mounted inside the house? The meter is 13-inch-long x 4-inch-wide x 4 inches tall. This is for a 1.5-inch water meter.
 - Pressure reducing valve is needed after the water meter.
 - Water meter needs to be accessible to the town for any service-related repairs.
 - If an irrigation system is being proposed an engineered plan must be submitted to the town and to the dept of health for approval.
 - Water meter must be kept in a temperature conditioned room
 - Curb stop will stay in the 20-foot easement of the Canandaigua consolidated water district. It appears to be brought to the end of the private drive.