

Chris Jensen

---

From: Chris Jensen <cjensen@townofcanandaigua.org>  
Sent: Thursday, April 29, 2021 11:40 AM  
To: 'Rocco Venezia'; 'craigpalmer777@gmail.com'  
Cc: 'Development Clerk'  
Subject: 4155 Woolhouse Road - Palmer

Good morning,

Assigned an address to the parcel:  
4155 Woolhouse Road

Comments:

- Driveway appears to be over 1,400ft. long.

**[NY] 511.2.2 Turnaround.** When driveways are in excess of 500 feet (152 400 mm) in length and do not exit to another fire apparatus access road or public street, a turnaround shall be provided suitable for use by fire apparatus.

**[NY] 511.2.3 Turnouts.** Driveways in excess of 500 feet (152 400 mm) in length and less than 20 feet (6096 mm) in width shall be provided with turnouts along the driveway that are a minimum 20 feet in width for a length of 50 feet (15 240 mm) in length. The turnouts shall be placed at intervals not to exceed 500 feet (152 400 mm) along the driveway.

**[NY] 511.2.4 Stability.** Driveways, including bridges and other supporting structures of driveways, shall be constructed to support fire apparatus in all weather conditions.

- verify stability of stream crossing to support fire apparatus
- Detail location of stream and stream crossing structure on plan. (culvert pipe?)

Thanks,  
Chris

Chris Jensen PE MCP, Code/Zoning Officer  
Town of Canandaigua  
Cell: (585) 315-3088