

# CANANDAIGUA LAKE WATERSHED COMMISSION

- City of Canandaigua
- Village of Rushville
- Village of Palmyra
- Village of Newark
- Town of Gorham

November 1, 2016

Donald J. & Elice Bowerman  
3933 N.Y.S. Route 5&20  
Canandaigua, New York 14424


Re: Property at:  
**Nott Road**  
Town of Canandaigua  
Tax Map No. 111.00-1-14.500

Dear Mr. & Ms. Bowerman:

This office has reviewed plans submitted by your engineer, Bernard G. Pulver, P.E. for a wastewater treatment (septic) system to serve a three (3)-bedroom residence at the property referenced above. The proposed system design is found to be in general compliance with applicable standards as required by the New York State Department of Health (NYSDOH) and the Canandaigua Lake Watershed Rules and Regulations and as such, the plans have been approved for installation. The system consists of a 1,250-gallon septic tank with an effluent filter, five (5)-drop boxes, and five (5)-leach lines 56 feet long for a total of 280 lineal feet of leach lines as shown on the enclosed plans.

This letter **IS NOT** to be construed as an approval of the installed system. Final approval of this wastewater treatment system will be subject to the following conditions:

1. **THAT** the system will be installed within three (3)-years of the date of this approval.
2. **THAT** notification is to be given to this office and the licensed professional responsible for the plan that the system is to be installed **AT LEAST TWO (2) BUSINESS DAYS** in advance of installation to allow inspections to be scheduled.
3. **THAT** the construction/installation of the facilities shall be in strict compliance with the approved plans.
4. **THAT** any minor deviation from the approved plans will require the approval of this office and the licensed professional responsible for the plans. Any major deviation from the proposed plans will require new submission of plans to this office. An additional review fee may be required.
5. **THAT** upon completion of construction, the licensed professional responsible for the plans will furnish this office with a signed "As-Built" plan and certification of construction compliance in accordance with the approved plans.

Sincerely,  
  
George V. Barden, CPESC  
Canandaigua Lake Watershed Inspector

✓ Chris Jensen – Town of Canandaigua Code Enforcement Officer w/plans  
Bernard G. Pulver, P.E. - Engineer w/plans

