Zoning Inspector

From:

Kevin L. Olvany <klo@canandaiguanewyork.gov>

Sent:

Friday, October 28, 2016 3:39 PM

To:

Zoning Inspector

Subject:

RE: Proposed Bowerman Residence - 0000 Nott Road

Bowerman residence:

The site plan shows a significant distance to the stream reducing the potential risk of impact. The sequence of construction will be important to follow to make sure the site is protected and stabilized. Straw mulch needs to be utilized on sites that stay disturbed for extended periods of time. The driveway access needs to be stabilized and the driveway drainage ditches need to be stabilized. We will monitor the site during rain events to make sure it is not an issue. Please have the applicant verify that the disturbance will be less than 1 acre.

Please let me know if you have any questions.

Kevin Olvany CPESC CPSWQ
Watershed Program Manager
Canandaigua Lake Watershed Council
205 Saltonstall St.
Canandaigua, NY 14424
585 396-3630
Kevin.Olvany@canandaiguanewyork.gov
yww.canandaigualake.org

From: Zoning Inspector [mailto:zoninginspector@townofcanandaigua.org]

Sent: Friday, October 28, 2016 2:22 PM

To: Kevin L. Olvany <klo@canandaiguanewyork.gov>

Subject: RE: Proposed Bowerman Residence - 0000 Nott Road

At www.townofcanandaigua.org go to bottom right hand corner of the page and click on "Board"

User: TOC
Password: town

Look for box 3rd down on right titled Bowerman

Eric A. Cooper

Zoning Inspector Town of Canandaigua ecooper@townofcanandaigua.org 585-394-1120

From: Kevin L. Olvany [mailto:klo@canandaiguanewyork.gov]

Sent: Friday, October 28, 2016 1:37 PM

To: Zoning Inspector < <u>zoninginspector@townofcanandaigua.org</u> > **Jubject:** RE: Proposed Bowerman Residence - 0000 Nott Road

Can you send me the web portal information?