

Development Clerk

From: Chris Jensen <cjensen@townofcanandaigua.org>
Sent: Wednesday, October 05, 2016 1:22 PM
To: jnesbitt@rochester.rr.com; dx872@aol.com
Cc: 'Eric Cooper'; 'Development Clerk'
Subject: Stablegate Drive 1945 - Proposed Pool

Good Afternoon,

We are in receipt of your application for an inground pool.

The section of the application that details the distance from the patio/sidewalk surrounding the pool was not detailed on the plan or application.

The sidewalk around the pool is also required to be 15ft. from the property boundary.

(e) Any structures or devices connected with the installation, maintenance or operation of a swimming pool, including but not limited to concrete or wood patio areas, pump and filter enclosures, bathhouses and cabanas, shall also comply with the setback requirements of this section.

Please come in to update application.

Thanks,
Chris

Chris Jensen PE
Code Enforcement / Zoning Officer
Town of Canandaigua - Development Office
5440 Routes 5 & 20 West
Canandaigua, NY 14424
(cell) 585-315-3088