

GREENE LAND SURVEYING, PLLC  
403 EAST MILLER STREET  
NEWARK, NEW YORK 14513  
OFFICE/ FAX (315) 331-3999

April 14, 2016

Mr. George V. Barden  
Canandaigua Lake Watershed Office  
480 North Main Street  
Canandaigua, New York 14424


**RE: 3356 HICKOX ROAD SITE PLAN (JOB NO. 15-3567)**  
**RESPONSE TO COMMENTS**

Dear Mr. Barden,

This letter is in response to your comment letter dated April 13, 2016. Our response to your comments are as follows:

1. The septic tank is sized for a garbage grinder, as stated in the Specification Legend.
2. The size of the septic tank was incorrect. The size has been revised to 1250 gallons.
3. A note has been added to the plan stating the two NYSDOH appendixes required for the proper removal of an existing well.
4. A shallow trench absorption trench detail has been added to the plans.
5. Greene Land Surveying, PLLC does not endorse the use of infiltrator chambers, therefore the detail has not been added to the plan.
6. The curtain drain detail has been added to the plan.
7. The reference to the design handbook date has been updated to the newest handbook edition.

Sincerely,



Michael G. Sponable, P.E.  
John A. Greene & Associates

Cc: Steve Parks