

From: Braun, Jack D <Jack.Braun@ontariocountyny.gov>
Sent: Thursday, January 7, 2021 3:46 PM
To: ecooper@townofcanandaigua.org
Subject: RE: Fox Ridge Subdivision
Attachments: 5B-3 Sketch.pdf

Hi Eric –

FYI, I sent some sanitary comments to Rocco and Erin last week – one of them asking them to realign the sewer main to provide as much horizontal separation from the storm sewer as possible, along with paralleling the westerly water main on a 10’ offset to the east with the end manhole on the westerly water transmission easement line (see attached). This should potentially alleviate the need for any agreements between the City and County.

We’ll see what comes back – tbc...

-jack

From: ecooper@townofcanandaigua.org [mailto:ecooper@townofcanandaigua.org]
Sent: Thursday, January 7, 2021 11:13 AM
To: 'Taylor A. Henry'; Braun, Jack D; Chris Nadler; Town Manager; 'Lance 'Brabant'; 'Fletcher, Jim Canandaigua Highway Superintendent'
Cc: 'John D. Goodwin'; 'David K. Hou'; 'James P. Sprague'; James, Arthur L; Havens, Donald E; 'Eric Cooper'; Chris Jensen
Subject: RE: Fox Ridge Subdivision

CAUTION: This message originated outside the Ontario County email system. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Taylor,

The Town Attorney Chris Nadler is ok with the conditions.

With regard to proposed improvements, the Town Highway and Water Superintendent has requested a revision to the proposed location of the future water main. As I understand the applicant is preparing that revision to the plans among some other items. When we receive those plans we will forward them on.

I believe we are still waiting for a response from the Developer to the requested conditions.

Let me know if there are unaddressed questions that remain at this point.

Eric A. Cooper

Planner

Town of Canandaigua

ecooper@townofcanandaigua.org

585-394-1120 x2254

From: Taylor A. Henry <thentry@boylancode.com>

Sent: Thursday, December 10, 2020 10:36 AM

To: Braun, Jack D <Jack.Braun@ontariocountynyny.gov>; ecooper@townofcanandaigua.org

Cc: John D. Goodwin <John.Goodwin@canandaiguanyork.gov>; David K. Hou <dhou@boylancode.com>; James P. Sprague <JPS@canandaiguanyork.gov>; James, Arthur L <Arthur.James@ontariocountynyny.gov>; Havens, Donald E <Donald.Havens@ontariocountynyny.gov>

Subject: RE: Fox Ridge Subdivision

Hi all,

Just to clarify, the Fox Ridge Subdivision will result in two easements that encroach on the City's existing water main easement – one that will eventually be held by the County Sewer District, the other by the Town. The subdivision will also result in the dedication of a road to the Town of Canandaigua that crosses over the easement. The City is completely willing to permit all of these improvements as long as the rights & obligations between all the parties are clear.

Specifically, the City is willing to acknowledge and permit the installation of the sanitary sewer as proposed on the condition that the developer (during installation) and the County (after transfer to the County) agree to (1) indemnify the City for any damages caused to the City's water line (during installation of the sanitary sewer & after transfer); (2) refrain from interfering or obstructing the City's ability to maintain and repair its water main; (3) provide the City with notice when/if any repairs are necessary; (4) release the City from any damages caused to the lands adjacent to the City's easement, including damages caused to the new sanitary sewer or other utility infrastructure that may be installed, that may occur in the course of the City's maintenance of its pre-existing water main easement; (5) permit the City to review the proposed easement granting the sewer line to the County prior to recording. The City will need an agreement among the itself, the developer & Town that contains the same provisions with respect to the easement that will eventually be held by the Town and the road to be dedicated to the Town.

To expedite the process, I would advise the City to sign off of the developer's plans as long as the County, developer, and Town agree to the above terms and the City's engineers are comfortable with the proposed location of the improvements from an engineering perspective. For this purpose, the City needs a survey identifying the location of the existing easement & proposed improvements. If these terms are acceptable to the Town, County, and Developer, (and the City approves the improvements from an engineering perspective), we can have the City acknowledge and approve the developer's plans for the County so that the developer's plans can move forward while the County's, Developer's, and City's counsel finalize written agreement(s) that include the terms I've laid out above.

If you'd like to schedule a Zoom call between the parties to discuss, I will make myself available as soon as you all need, just let me know.

Thank you!

Taylor

Taylor A. Henry, Esq.

Associate



Culver Road Armory
145 Culver Road, Suite 100
Rochester, New York 14620
Office: 585-238-3531
Fax: 585-232-3528

Email: thenry@boylanocode.com

Web: www.boylanocode.com

From: Braun, Jack D <Jack.Braun@ontariocountyny.gov>

Sent: Friday, December 04, 2020 9:50 AM

To: Taylor A. Henry <thenry@boylanocode.com>; ecooper@townofcanandaigua.org

Cc: John D. Goodwin <John.Goodwin@canandaiguaneuwyork.gov>; David K. Hou <dhoul@boylanocode.com>; James P. Sprague <JPS@canandaiguaneuwyork.gov>; James, Arthur L <Arthur.James@ontariocountyny.gov>; Havens, Donald E <Donald.Havens@ontariocountyny.gov>

Subject: RE: Fox Ridge Subdivision

Good morning all –

I think a bit of clarification is necessary – it's the County, or more specifically, the Canandaigua Lake County Sewer District that will ultimately assume ownership of the sanitary sewer that crosses the City's water main and encroaches their easement. From a legal standpoint, it's unclear whether the Town has any involvement.

For their information, I have included the County's attorney as well as the District Supervisor in this distribution.

-jack

John D. Braun
Junior Engineer, CLCSD

Ontario County Department of Public Works
2962 County Road 48
Canandaigua, New York 14424
(585) 396-4049

From: Taylor A. Henry [<mailto:thenry@boylanocode.com>]

Sent: Thursday, December 3, 2020 11:11 AM

To: ecooper@townofcanandaigua.org

Cc: John D. Goodwin; David K. Hou; James P. Sprague; Braun, Jack D

Subject: Fox Ridge Subdivision

CAUTION: This message originated outside the Ontario County email system. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Eric,

We are Corporation Counsel for the City; I am touching base about the Fox Ridge Subdivision water main easement issue. Per Jim Sprague's October 28 memo, the City is ok with the proposed installation, but in order to proceed, the City will need an agreement between the Town, Developer, and City to govern each party's rights & responsibilities with respect to the overlapping easements. Specifically, the Town & Developer will need to agree to indemnify the City for any damages caused to the City's main (or repairs to the City's main made necessary) by the Developer (during construction) or the Town (after transfer of the easement to the town). If acceptable, we can prepare that document.

The City will also need to confirm the exact location of the existing main & the proposed – please forward a survey map that depicts the same. I understand all parties are eager to get this wrapped up – I will give you a call this afternoon to discuss.

Thanks,
Taylor

Taylor A. Henry, Esq.
Associate



Culver Road Armory
145 Culver Road, Suite 100
Rochester, New York 14620
Office: 585-238-3531
Fax: 585-232-3528
Email: thentry@boylancode.com
Web: www.boylancode.com

This disclosure is required by the IRS:

Tax advice in this e-mail, including any attachments, is not intended or written to be used, and cannot be used to avoid penalties imposed under the Internal Revenue Code or to promote, market or recommend to another person any tax related matter. If you would like advice that can be used for either of these purposes please contact us about what that would require.

This message contains confidential information and is intended only for listed recipient(s). If you are not the intended recipient you should not disseminate, distribute or copy this e-mail. Please notify the message sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. Boylan Code therefore does not accept liability for any errors or omissions in the contents of this message, which arise as a result of e-mail transmission. If verification is required please request a hard-copy version.

“This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.”

This disclosure is required by the IRS:

Tax advice in this e-mail, including any attachments, is not intended or written to be used, and cannot be used to avoid penalties imposed under the Internal Revenue Code or to promote, market or recommend to another person any tax related matter. If you would like advice that can be used for either of these purposes please contact us about what that would require.

This message contains confidential information and is intended only for listed recipient(s). If you are not the intended recipient you should not disseminate, distribute or copy this e-mail. Please notify the message sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. Boylan Code therefore does not accept liability for any errors or omissions in the contents of this message, which arise as a result of e-mail transmission. If verification is required please request a hard-copy version.